

Test Report

Report No: ASH15-005515-01

Date: Mar 09 2015

TEST RESULT(S):

Code	Test items	Unit	Test method	Test results	MDL	Parametric value*1 (98/83/EC)
1	Coliform	cfu/100mL	ISO 9308-1:2000	< 1	/	0
2	Escherichia coli	cfu/100mL	ISO 9308-1:2000	< 1	/	0
3	Arsenic (As)	µg/L	EPA 200.8	2	1	10
4	Cadmium (Cd)	µg/L	EPA 200.8	Not detected	1	5.0
5	Chromium(Cr)	µg/L	EPA 200.8	Not detected	1	50
6	Copper (Cu)	mg/L	EPA 200.8	Not detected	0.006	2.0
7	Lead (Pb)	µg/L	EPA 200.8	Not detected	1	10
8	Mercury (Hg)	µg/L	EPA 200.8	Not detected	1	1.0
9	Aluminium (Al)	µg/L	EPA 200.7	72	10	200
10	Iron (Fe)	µg/L	EPA 200.7	Not detected	7	200
11	Manganese (Mn)	µg/L	EPA 200.7	Not detected	5	50
12	Color	/	ISO 7887:1994	< 5	/	Acceptable to consumers and no abnormal change
13	Turbidity	NTU	APHA2130B	0.6	/	Acceptable to consumers and no abnormal change

Remark:*1 The parametric value refers to COUNCIL DIRECTIVE 98/83/EC of 3 November 1998 on the quality of water of water intended for human consumption. The directive applies to drinking water, but does not include natural mineral water and medical products.

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.

Page 2 of 3

RAND: 3772816



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SHAF

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.
Testing Center, China Inspection & Certification Laboratory

3rd Building, No. 889, Yishan Road, Shanghai, China 200233 tel (86-21)6140 2501 fax (86-21) 6140 2547 www.sgs.com.cn
中国·上海·宜山路889号3号楼 邮编:200233 tel (86-21)6140 2501 fax (86-21) 6140 2547 email sgs.china@sgs.com

Member of the SGS Group (SGS SA)



Test Report

Report No: ASH15-005515-01

Date: Mar 09 2015

SAMPLE DESCRIPTION: Water Filter Straw

ASH15-005515.001



*** End of Report***

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.

Page 3 of 3

RAND: 3772816



SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.
Testing Center (Shanghai) Laboratory

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and for electronic format documents subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SHAF

3rd Building, No. 889, Yishan Road, Shanghai, China 200233

tel (86-21)6140 2501 fax (86-21) 6140 2547

www.sgs.com

中国·上海·宜山路889号3号楼

邮编:200233

tel (86-21)6140 2501 fax (86-21) 6140 2547

email sgs.china@sgs.com

Member of the SGS Group (SGS SA)